

THIS ENDORSEMENT CHANGES THE CERTIFICATE  
PLEASE READ IT CAREFULLY

**ENDORSEMENT D - PROTECTIVE SAFEGUARDS**

This endorsement modifies insurance provided under the following:

**COMMERCIAL PROPERTY COVERAGE PART**

A. The following is added to the:

Commercial Property Conditions

**PROTECTIVE SAFEGUARDS**

1. As a condition of this insurance, you are required to maintain the protective devices or services. – See *KRS 56.170*
2. The protective safeguards to which this endorsement applies are identified by the following symbols:

**"P-1" Automatic Sprinkler System**, including related supervisory services.

Automatic Sprinkler System means:

- a. Any automatic fire protective or extinguishing system, including connected:
  - (1) Sprinklers and discharge nozzles;
  - (2) Ducts, pipes, valves and fittings;
  - (3) Tanks, their component parts and supports; and
  - (4) Pumps and private fire protection mains.
- b. When supplied from an automatic fire protective system:
  - (1) Non-automatic fire protective systems; and
  - (2) Hydrants, standpipes and outlets.

**"P-2" Automatic Fire Alarm**, protecting the entire building, that is:

- a. Connected to a central station; or
- b. Reporting to a public or private fire alarm station.

**"P-3" Security Service**, with a recording system or watch clock, making hourly rounds covering the entire building, when the premises are not in actual operation.

**"P-4" Service Contract** with a privately owned fire department providing fire protection service to the described premises.

**"P-9"** The protective system described in the Schedule.

B. The following is added to the EXCLUSIONS section of:

**CAUSES OF LOSS – SPECIAL FORM**

We will not pay for loss or damage caused by or resulting from fire if, prior to the fire, you:

1. Knew of any suspension or impairment in any protective safeguard listed in the Schedule above and failed to notify us of that fact; or
2. Failed to maintain any protective safeguard listed in the Schedule above, and over which you had control, in complete working order.

If part of an Automatic Sprinkler System is shut off due to breakage, leakage, freezing conditions or opening of sprinkler heads, notification to us will not be necessary if you can restore full protection within 48 hours.