

# Electronic Safety & Security - Owner's Project Requirements

Division 280000-2

<b>Reference</b>	<b>Specification Requirements</b>
	General MEP Standards

<b>Reference</b>	<b>Systems Basis of Design Requirements</b>

<b>Reference</b>	<b>Design Requirements</b>
	Locate cable routing paths on project drawings and identify acceptable cable retaining methods and details.
	Fire alarm zones should correspond with sprinkler system zones and be identified on drawings showing interface to other building system components.

<b>Reference</b>	<b>Functional Requirements Tab</b>
	General MEP Standards

<b>Reference</b>	<b>Administrative Requirements</b>
	General MEP Standards