GENERAL NOTES AND EQUIPMENT SCHEDULE

FIRE CONTROL PANEL L.C.P.-7

HOTEL VAV SYSTEM — TO MAIN MECH. ROOM - L.C.P. #1 - SEE SHEET #1 CABLE #60

HOTEL CORRIDOR — TO MAIN MECH. ROOM - L.C.P. #2 - SEE SHEET #3 CABLE #61

SWIMMING POOL — TO SWIMMING POOL MECH ROOM - L.C.P. #3 - SEE SHEET #5 CABLE #71

STAIRWELL SOUTH — TO SOUTH STAIRWELL - (SAME AS STAIRWELL NORTH) L.C.P. #3 - SEE SHEET #5 CABLE #72

STAIRWELL NORTH

NORTH STAIRWELL PRESSURIZATION FAN (TYPICAL FOR STAIRWELL SOUTH)

CABLE #5

CABLE #73

B-4 MECH RM

B-5 MECH. RM. (SAME AS B-4)

24 VAC TO ALL L.C.P.'S

120 VAC

FIRE CONTROL PANEL

VAV EXHAUST 1 | HOTEL CORRIDOR | SWIMMING POOL | STAIRWELL SOUTH | STAIRWELL NORTH | DUAL DUCT SYSTEM B4 | DUAL DUCT SYSTEM B5

ON / OFF / MAN OFF AUTO

AE-631 (24"W X 32"H X 7"D)

PANEL LAYOUT
FRONT VIEW
NTS

TYPICAL FOR NORTH & SOUTH STAIRWELL PRESSURIZATION FAN

R-2-1 | R-3-2 | R2-2 | EF | 110V | R-3

4894

FIRE CONTROL PANEL L.C.P.-7	
DRAWN BY	J.G.
CHECKED	L.G.
DATE	10-31-83
	83-74943-11

— REVISIONS — DATE	CHANGES
1-24-84	REVISED STAIRWELL NORTH
3-21-84	"AS BUILT"

JOB NAME CAPITOL PLAZA HOTEL
LOCATION FRANKFORT, KY.
ARCHITECT N/A
ENGINEER CARTER & FOSTER & ASSOCIATES
CONTRACTOR STEWART MECHANICAL

FIELD OFFICE — Louisville Branch, 1651 Watterson Trail, Jeffersontown, Kentucky 40299, 502—267-5003

SHEET 11 OF 16

F-2869-3

GENERAL NOTES AND EQUIPMENT SCHEDULE

DRYER MAKE-UP SF2

EP 100 | EP 66 | EP 33 | LL1 | NEU

D1 | D2 | PURP | RED | BRN | 110V GAS VALVE | 110 GAS VALVE

PC-110 | SF2 | AUX | 120VAC SOURCE

E/P-33 | E/P-66 | E/P-100 | E/P SF | AL-110 | 9.5 | 11.5

STEP VANE | D-21 | MK-3121 | O.A. | D-22

LCP-6 AE-630(16"W X 24"H X 7"D)

GENERATOR ROOM

120VAC SOURCE | GENERATOR CONTACT | AL-110 | M | NC | D-25 | MK-3121 | C.A.

D-26 | D-27 | D-28 | D-29 | 3-EX FANS | MK-3121 | RA | TK-1001

DISHWASHER EX EF 4 & EF 6

AL-110 | WIRE TO EX FAN | M | D-23 | MK-4421

RED | BRN | ORG | L.O.W. SW. | 120VAC SOURCE | ELECTRIC T/H | FLR DRN | ELEV. T/H | TC-1101-403 (3 REQ'D)

MECH. EQUIP. RM.

PC-110 | START EF-5 | AK-50401 | D-24 | MK-3121 | M | M.B | TK-5001 | AT-532-111-1-01

VESTIBULE 101-152

120 VAC SOURCE | NEW | LI | PC-110 | M | M.B | TK-5001

RED | BRN | ORG | L.O.W. SW. | LL1 | NEU | 120VAC SOURCE | TC-1101-403 | MA-418-500 | EF-10

ELEVATOR PH EXHAUST

4894

DRYER MAKE-UP SF2, GENERATOR, DISH-WASH EF4 & EF6, MECH. EQUIP. RM, ELEV. VESTIBULE, ELEVT. RM.	
DRAWN BY	J.G.
CHECKED	L.G.
DATE	10-24-83
	83-74943-10

— REVISIONS — DATE	CHANGES
2-9-84	MISC CHGS
3-21-84	"AS BUILT"

JOB NAME CAPITOL PLAZA HOTEL
LOCATION FRANKFORT, KY.
ARCHITECT N/A
ENGINEER CARTER & FOSTER & ASSOCIATES
CONTRACTOR STEWART MECHANICAL

FIELD OFFICE — Louisville Branch, 1651 Watterson Trail, Jeffersontown, Kentucky 40299, 502—267-5003

SHEET 10 OF 16

F-2869-3